

# **Demand Savings Analysis Solar + Battery Projects**

**what we have learned from our operating portfolio  
and  
how to stress test financial models using performance data**

**Ali Chehrebsaz  
Dan Rosenberg**

there is a lot of excitement in the  
battery storage market!

behind the meter battery  
installations are expected to  
provide electricity bills savings by  
reducing electricity demand  
charges

additionally, solar **plus** battery storage installations are expected to provide more savings by reducing both usage and demand charges

as battery storage is a new market, there are varying methods in projecting combined solar plus battery storage installations

this presentation is designed to describe how TerraVerde projects demand savings from battery installations when paired with a solar installation by relying on performance data from our operating portfolio

we will first start with background  
information and work our way  
through a case study

to assess the savings projection,  
we first need to understand how  
an electricity bill is calculated



electricity costs are calculated  
based on the **rate schedule**  
applied to each utility electricity  
meter

the rate schedule is primarily  
determined by the **usage profile**  
measured by the meter

rate schedule = func(**usage profile,**  
**customer type,**  
**voltage**<sub>interconn</sub>,  
**etc.**)

the usage profile is the measure  
of how fast, how much, and time  
of use of electricity

to better understand all the details involved in a rate schedule you will need to thoroughly read the documentation provided by the electric utility

the next slide shows the  
Southern California Edison TOU-  
GS3 rate schedule and all the  
components that need to be  
factored into calculating the  
electricity bill



Southern California Edison  
Rosemead, California (U 338-E)

Revised Cal. PUC Sheet No. 57829-E  
Cancelling Revised Cal. PUC Sheet No. 57442-E

**Schedule TOU-GS-3**  
**TIME-OF-USE - GENERAL SERVICE - DEMAND METERED**

Sheet 3

(Continued)

**RATES**

The rates below will apply to all customers receiving service under this Schedule. In addition, the customer will be charged the applicable rates under CPP, Option A, Option B or Option R, as listed below. Except for the customer's firm load that is designated as the Capacity Reservation Level (CRL), CPP Event Charges will apply to all remaining load during CPP Events and CPP Non-Event Credits will apply to all remaining load during CPP Non-Events, as described in Special Conditions 1 and 3, below.

	Delivery Service							Generation <sup>a</sup>		
	Trans <sup>1</sup>	Distrib <sup>2</sup>	NSGC <sup>3</sup>	NDC <sup>4</sup>	PPPC <sup>5</sup>	DWRBC <sup>6</sup>	PUCRF <sup>7</sup>	Total <sup>8</sup>	UG <sup>**</sup>	DWREC <sup>10</sup>
<b>Option CPP</b>										
Energy Charge - \$/kWh/Meter/Month										
Summer Season On-Peak	0.00018	0.00302	0.00835	0.00028	0.00995 (R)	0.00526	0.00024	0.02728 (R)	0.10804 (R)	(0.00172)
Mid-Peak	0.00018	0.00302	0.00835	0.00028	0.00995 (R)	0.00526	0.00024	0.02728 (R)	0.05913 (R)	(0.00172)
Off-Peak	0.00018	0.00302	0.00835	0.00028	0.00995 (R)	0.00526	0.00024	0.02728 (R)	0.03584 (R)	(0.00172)
Winter Season On-Peak										
Mid-Peak	0.00018	0.00302	0.00835	0.00028	0.00995 (R)	0.00526	0.00024	0.02728 (R)	0.06073 (R)	(0.00172)
Off-Peak	0.00018	0.00302	0.00835	0.00028	0.00995 (R)	0.00526	0.00024	0.02728 (R)	0.04064 (R)	(0.00172)
Customer Charge - \$/Meter/Month		441.93						441.93		
Demand Charge - \$/kW of Billing Demand/Meter/Month										
Facilities Related	3.66	12.71						16.37		
<b>Time Related</b>										
Summer Season - On-Peak		0.00						0.00	18.10 (R)	
Mid-Peak		0.00						0.00	5.31 (R)	
Winter Season - On-Peak		0.00						0.00	0.00	
Mid-Peak		0.00						0.00	0.00	
<b>Voltage Discount, Demand - \$/kW</b>										
Facilities Related										
From 2 kV to 50 kV	0.00	(0.20)						(0.20)		
Above 50 kV but below 220 kV	0.00	(6.71)						(6.71)		
At 220 kV	0.00	(12.71)						(12.71)		
Time Related										
From 2 kV to 50 kV	0.00	0.00						0.00	(0.32) (R)	
Above 50 kV but below 220 kV	0.00	0.00						0.00	(0.91) (R)	
At 220 kV	0.00	0.00						0.00	(0.92) (R)	
<b>Voltage Discount, Energy - \$/kWh</b>										
From 2 kV to 50 kV	0.00000	0.00000						0.00000	(0.00104) (R)	
Above 50 kV but below 220 kV	0.00000	0.00000						0.00000	(0.00232) (R)	
At 220 kV	0.00000	0.00000						0.00000	(0.00234) (R)	
<b>Power Factor Adjustment - \$/kVAR</b>										
Greater than 50 kV		0.34						0.34		
50 kV or less		0.51						0.51		
<b>California Alternate Rates for Energy Discount - %</b>										
Energy Discount - %		100.00 <sup>*</sup>						100.00 <sup>*</sup>		
<b>CPP Event Energy Charge - \$/kWh</b>										
Summer CPP Non-Event Credit									1.37453	
On-Peak Demand Credit - \$/kW									(11.44)	
<b>Maximum Available Credit - \$/kW<sup>**</sup></b>										
On-Peak									(21.57) (R)	
Mid-Peak									(6.32) (R)	

(Continued)


the rate schedule components  
can be summarized into three  
categories:

- Usage or kWh charges
- Demand or kW charges
- Fixed charges



the ratio of three categories for the building in our case study are shown in the following pie chart

# Electricity Bill



■ fixed charges    ■ kW charges    ■ kWh charges

**usage charges** are the sum of total electricity drawn from the grid and measured in kWh

**demand charges** are calculated based on the maximum demand for each month measured in kW during any 15-minute interval

**fixed charges** are the sum of  
non variable costs including meter  
costs


now that the basics of an  
electricity bill are covered, let's  
jump into the analysis

this presentation will walk  
through the following three  
savings analysis for:


- solar only savings
- battery only savings
- solar + battery savings

let's start by showing a block diagram of typical behind-the-meter solar installation






school




switchgear


utility meter



electric grid




the graph on the next slide  
shows the solar production and  
building load profiles for a typical  
school day



the building load reduction **plus**  
the excess solar production  
delivered to the grid results in  
electricity bill savings which are  
shown on the next slide

# Post Solar Electricity Bill



as shown on the last slide the solar installation is capable of reducing the entire usage (kWh) charges of the electricity bill

solar installations are also able to reduce the instantaneous building demands, however demand (kW) savings are not accounted in savings projections due to intermittent nature of solar production

why does the solar production  
**intermittency risk** prevent  
accounting for demand savings?




remember, **demand charges** are  
calculated based on the  
maximum demand (kW) for each  
month as measured during any  
15-minute interval

therefore, temporary cloud coverage during a typical operational day that reduces solar production would result in a demand spike measurement on the utility meter

since the utility bills for demand charges for the one time highest 15-minute interval per month, the load spike during the could event would set the maximum demand for the month

back to the bill, the next slide  
shows the electricity bill pre and  
post solar

## pre/post Solar Electricity Bill




if all assumptions hold, the electricity bill would be reduced to \$35,295 (sum of kW charges and Fixed charges) per year for the life of the solar installation

unfortunately, the kW charges are expected to increase and as a result the post solar electricity bill will continue to increase

the next slide shows the growth of the kW charges in SCE territory for a sample of the rate schedules




SCE Max Demand Increases (2011-2015)




to reduce the impact of kW  
charge increases and provide  
additional savings on the  
electricity bill we will look to  
battery storage systems

before we see how a battery system complements a solar system, let's first look at a stand alone battery system

the next slide shows a block  
diagram of a behind-the-meter  
battery installation




the graph on the next slide  
shows the charge/discharge and  
building load profiles for a battery  
installation



the building max demand  
reduction per month results in kW  
charge reductions as shown on  
the next slide




# Post Battery Electricity Bill



the electricity bill savings as a  
result of demand reduction is  
shown next

## pre/post Battery Electricity Bill



as shown on the last slide, the  
kW charges are reduced by  
\$5,031 on an annual basis


you may have noted a small increase in kWh charges; the increase is due to round-trip efficiency losses of the battery

we have now covered the basics  
of stand alone behind-the-meter  
solar and battery installations


let's get into the exciting portion  
of the presentation and show  
what happens when solar and  
battery installations are paired!

again, we will start with a block  
diagram






and next is the demand and usage profiles of the same building for the same day; scroll back up to compare the profile differences



■ Solar Production   
 ■ Discharged Electricity   
 ■ Re-charged Electricity   
 — Building Demand   
 — Post Solar & Battery Demand

the next slide shows the  
reductions in kWh and kW  
charges as a result of solar and  
battery installations

# Post Solar and Battery Electricity Bill




you may have also noticed in  
reduction in Fixed charges which  
is due to rate schedule change

in this scenario, the combination of solar and battery installations result in sufficient demand reduction to allow the building to switch from a GS3 to a GS2 rate schedule which has lower Fixed, kW, and kWh charges

the next slide shows the  
electricity bill savings from solar  
and battery combination in  
comparison to previous scenarios



## pre/post Electricity Bill



the savings exhibit a compelling  
argument for pairing solar with  
battery installations

the remaining electricity bill is a  
fraction of the original bill

while the opportunity and cost savings look attractive, it is critical to explore the assumptions behind the savings projections

a key assumption explored in this presentation is the intermittent performance of solar installations and the impact on battery demand reduction

when projecting demand  
reductions in solar plus battery  
installations, the model assumes  
typical year solar production

the typical year solar model for  
this scenario would result in  
monthly demand reductions  
ranging from min 5% in  
December to max 66% in April

that means solar production  
without the help of a battery is  
capable of creating demand  
reduction and therefore kW  
charge savings, **if typical  
performance is realized** per  
models




this is a highly optimistic  
assumption which we are able to  
modify based on the performance  
data from our portfolio of  
operating solar installations

the data presented is collected  
from the operating solar  
installations managed by  
TerraVerde

the boxplot on the next slide shows the percentiles of max demand reduction, by month, for all of our portfolio sites


## Monthly Distributions of Demand Reductions



Boxplot range represent 0<sup>th</sup>, 25<sup>th</sup>, 50<sup>th</sup>, 75<sup>th</sup>, and 100<sup>th</sup> percentiles

the following slide shows the  
same data but the sites are  
grouped by portfolio of financed  
projects

### Monthly Distribution of Demand Reductions Grouped by Financing Portfolio




Boxplot range represent 0<sup>th</sup>, 25<sup>th</sup>, 50<sup>th</sup>, 75<sup>th</sup>, and 100<sup>th</sup> percentiles

as shown from the last slide, the range of the average demand reduction gets much smaller when a portfolio of installations are evaluated

the upcoming slide shows how  
much maximum demand  
decreases, depending on the  
hour when it occurs




## Hourly Distribution of Demand Reduction



Boxplot range represent 0<sup>th</sup>, 25<sup>th</sup>, 50<sup>th</sup>, 75<sup>th</sup>, and 100<sup>th</sup> percentiles

the following slide shows what  
time of day maximum demand  
occurs with and without solar


# Solar Shifts Time of Demand



as seen on the previous slides, a solar installation is capable of reducing and shifting peak demand

the following slide is a heat map showing the expected reduction in demand based on the month and hour it occurs

# Average Demand Reduction Percentage



the peak demand reduction due  
to solar generation in our portfolio  
ranges from

@25 <sup>th</sup> Percentile	5% to 32%
@50 <sup>th</sup>	8% to 39%
@75 <sup>th</sup>	9% to 43%


as shown in the last slide, the peak demand reduction observed from operating solar installations is lower in most months than the modeled values based on TMY data



therefore, to avoid over-estimating savings, we apply the 25<sup>th</sup> and 50<sup>th</sup> percentile limits to the post solar demand profile prior to testing the peak demand reduction using a battery installation

the next slide shows the  
reduction in savings from the  
theoretical scenario assuming  
perfect solar performance per  
TMY data

## Residual Electricity Bill Scenarios



as seen above, the residual  
electricity bill for the 25<sup>th</sup>  
percentile scenario is increased  
by \$4,532 per year (43%) as  
compared to the TMY model  
savings

the reduced ***projected*** savings  
from the combined solar and  
battery reduces the return on  
investment for the project

while the reduced ROI is less attractive, it should be treated as a sound stress test of the financial models and part of the due diligence process

in closing, we would like to  
remind you that the data  
presented here are from our  
operating solar portfolio with a  
system uptime of >99%

additionally, the portfolio  
presented is specific to California  
public school districts in various  
climate zones



to perform a stress test on the financial return of solar and battery installations the analysis must be based on dataset collected from applicable buildings in similar climate zones

finally, we need to emphasize for simplicity of presentation, we omitted to highlight other benefits of combined solar and battery installations including charge/discharge arbitrage and Demand Response opportunities

# About TerraVerde Renewable Partners

**Since 2009, TerraVerde has been California's leading independent solar energy advisor**

Recognized leader in project development consulting services in Energy Efficiency, Solar, and Energy Storage  
Unique engagement model mitigates project risks during development

In house engineering, structured finance, financial modeling, Design-Build & PPA contracts, owner's representative project management, and Asset Management

Completed the first solar plus battery storage school project in California for Burton City Schools in Porterville and several more under installation and development

# Contact Information

**Ali Chehrebsaz, EVP Operations**

**TerraVerde Renewable Partners, LLC**

1100 Larkspur Landing, Suite 155

Larkspur, CA 94939

[Ali.Chehrebsaz@tvrpllc.com](mailto:Ali.Chehrebsaz@tvrpllc.com)